

कार्यालय सहायक यंत्री
लोक स्वास्थ्य यांत्रिकी उपखण्ड, खरगोन

क्रमांक / २०७ / स.य. / जि.ज.प.प्र. / 2026
प्रति,

खरगोन, दिनांक 15/04/2026

कार्यपालन यंत्री
लोक स्वास्थ्य यांत्रिकी,
खण्ड खरगोन

✓ 15/4/26
S E/S A/S T/C

Adtr/Kgn/Ked/Brh/Bkn

Steno

D.A.D

E.E


विषय :- जल परीक्षण रिपोर्ट प्रेषित करने विषयक।

संदर्भ :- आपका पत्र क्रमांक 53 / 2026 खरगोन दिनांक 06.04.2026 के संबंध में।

—00—

उपरोक्त संदर्भित विषयान्तर्गत में लेख है कि आपके द्वारा शासकीय कन्या शिक्षा परिसर खरगोन संस्था में प्रदायित नल के पानी (टयुबवेल) का जल नमुना भेजा गया था। जिसका जिला जल परिक्षण प्रयोगशाला खरगोन में परीक्षण कर परीक्षण रिपोर्ट आपकी ओर प्रेषित है।

संलग्न :- परिक्षण रिपोर्ट।


सहायक यंत्री,
लोक स्वास्थ्य यांत्रिकी उपखण्ड
खरगोन (म.प्र.)

**District Water Testing Laboratory,
Public Health Engineering Department,
Diversion Road, Khargone, 451001, Phone-07282-232875
Test Report**

Nature of sample :- Drinking Water Sample / Others		Sample Not collected by District Lab		Unique Identification No.
प्रति, शासकीय कन्या शिक्षा परिसर खरगोन जिला खरगोन म.प्र.	Sender's letter no. DWTL Ref. No	53/2026	07	09/04/2026
	Date of analysis started	09/04/2026		09/04/2026
	Quantity Of sample	1 liter		13/04/2026

Sample Details

No.	Particulars of Samples
1	शासकीय कन्या शिक्षा परिसर खरगोन के संस्था में प्रदायित नल के पानी (टयुबवेल) का जल नमूना
-	-
-	-
-	-
-	-

Sample details

No.	Characteristics , unit and test methods	BIS -10500:2012		RESULTS	
		Desirable Limit	Permissible Limit	1	
1	Temperature in degree C				-
2	Colour in Hazen scale				-
3	Odour	5	15	Nil	-
4	Iron as Fe in mg/l, IS 3025, Part -53	Agreeable	Agreeable	Agreeable	-
5	Nitrate as NO3 in mg/l, PDA Method	1.0	1.0	0.02	-
6	Fluoride as F in mg/l IS 3025, Part -60	45	45	5.14	-
7	Chloride as Cl in mg/l, IS 3025, Part-32	1.0	1.5	0.0	-
8	Total Alkalinity as CaCO ₃ in mg/l, IS 3025, Part -23	250	1000	99.6	-
9	Calcium as Ca++ in mg/l, IS 3025, Part -40	200	600	121.2	-
10	Magnesium as Mg++ in mg/l, IS 3025, Part -46	75	200	44.4	-
11	Sulphate as SO4 in mg/l, BIS:3025 (Part -24)	30	100	21.4	-
12	pH APHA 22 nd IS 3025, Part -11	200	400	28.0	-
13	Turbidity in NTU, IS 3025, Part-10	6.5 to 8.5	6.5 to 8.5	7.05	-
14	Total hardness as CaCO ₃ in mg/l, IS 3025, Part-21	1.0	5.0	2.0	-
15	Conductivity at 25°C in micromhos /cm, IS 3025, Part-14	200	600	242.0	-
16	TDS By meter IS 3025, Part-16	-	-	797	-
17	Phenolphthalein Alkalinity as CaCO ₃ in mg/l IS 3025, Part	500	2000	412	-
18	Faecal Coliform (TTC) per 100 ml IS APHA23 rd edition, 9211 B	-	-	-	-
19	Total coliform per 100 ml IS APHA23 rd edition 9211 B	NIL		-	-
		NIL for treated water and water in distribution system		Nil	-

1. This report should not be produced partly or full without approval of signatory authority for legal purposes.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters tested
4. Samples will be stored for a period of 10 days from the date of issue of report. (For tests from S.No. 1 to -----)



Chemist
DISTRICT LABORATORY
P. H. E. DEPARTMENT KHARGONE

Annexure C

कार्यापालन यंत्री
लोक स्वास्थ्य यांत्रिकी खण्ड
खरगोन (म.प्र.)

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 209

Dated: 09/04/2026

It is certified that an inspection team headed by Ramchandra Yadav

(Name of Officers with designation) from Chemist PHED

inspected the Govt. Kanya Shiksha Parisar Khargone

(Name & Address of the school) on 09/04/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 07/D.W.T. dated 09/04/2026

of P.H.E.D./D.W.T./2026 (PHED Lab) certified that

the Govt. Kanya Shiksha Parisar Khargone (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 16/07/2026

Signature with Seal: Executive Engineer

Name: Public Health Engg. Division

Designation: P.H.E.D.

Name & Address of the Office / Department :

To
Govt. Kanya Shiksha Parisar
Khargone
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies